

Monthly Fire Extinguisher Checks

Check these details during a monthly fire extinguisher inspection:

- ✓ Confirm the extinguisher is visible, unobstructed, and mounted to the wall.
- ✓ Verify the locking pin is intact and the tamper seal is unbroken. Examine the extinguisher for obvious physical damage, corrosion, leakage, or clogged nozzle.
- ✓ Confirm the pressure gauge arrow is within the green zone, and lift the extinguisher to ensure it is still full.
- ✓ Check the last professional service date on the tag. A licensed fire extinguisher maintenance contractor must have inspected the extinguisher within the past 12 months.
- ✓ Initial and date the back of the tag.

