


# Ultrahigh-Resolution Fiber-Optic Sensing Based on High-Finesse, Meter-Long Fiber Fabry-Perot Resonators

Volume 12, Number 3, June 2020

Nabil Md. Rakinul Hoque  
Lingze Duan, *Senior Member, IEEE*



DOI: 10.1109/JPHOT.2020.2974628

# Ultrahigh-Resolution Fiber-Optic Sensing Based on High-Finesse, Meter-Long Fiber Fabry-Perot Resonators

Nabil Md. Rakinul Hoque   
and Lingze Duan , *Senior Member, IEEE*

Department of Physics and Astronomy, The University of Alabama in Huntsville, Huntsville,  
AL 35899 USA

DOI:10.1109/JPHOT.2020.2974628

This work is licensed under a Creative Commons Attribution 4.0 License. For more information, see <http://creativecommons.org/licenses/by/4.0/>

Manuscript received January 19, 2020; revised February 11, 2020; accepted February 13, 2020. Date of publication February 20, 2020; date of current version June 22, 2020. This work was supported in part by the National Science Foundation under Grants ECCS-1254902 and ECCS-1606836 and in part by the National Aeronautics and Space Administration under Grant 80NSSC19M0033. Corresponding author: Lingze Duan (e-mail: lingze.duan@uah.edu).

**Abstract:** Ultrahigh-resolution fiber-optic sensing has found a wide range of potential applications. However, the techniques reported so far are all based on highly specialized fiber structures and interrogation lasers, which are not widely available. In this paper, we report the demonstration of ultrahigh strain resolutions using only off-the-shelf commercial components. Our method leverages the high wavelength discrimination of long, high-finesse fiber Fabry-Perot interferometers (FFPI), using two 1 m-long FFPIs, one as the sensor and the other as a frequency reference. By locking the interrogation laser to the reference interferometer, which is co-packaged with the sensor interferometer, large, environment-induced sensing background is removed. This allows the laser to reliably probe the strains applied on the sensor with very high resolutions. A nominal, noise-limited strain resolution of  $800 \text{ fe}/\sqrt{\text{Hz}}$  has been achieved within 1–100 Hz. Strain resolution further improves to  $75 \text{ fe}/\sqrt{\text{Hz}}$  at 1 kHz,  $60 \text{ fe}/\sqrt{\text{Hz}}$  at 2 kHz and  $40 \text{ fe}/\sqrt{\text{Hz}}$  at 23 kHz, demonstrating better resolutions than proven techniques such as  $\pi$ -phase-shifted and slow-light fiber Bragg gratings. The work lays out a cost-effective scheme to achieve ultrahigh-resolution fiber-optic sensing.

**Index Terms:** Fabry-Perot interferometers, optical fiber sensors, optical resonators, strain measurement.

## 1. Introduction

Passive fiber-optic sensors such as fiber Bragg gratings (FBG) and fiber Fabry-Perot Interferometers (FFPI) have demonstrated tremendous potential to achieve ultrahigh-resolution (UHR) optical sensing [1], [2]. Most high-resolution fiber-optic sensors share similar working principles. When external disturbance (e.g., longitudinal strain or temperature fluctuation) is applied, internal parameters such as grating period, cavity length and refractive index are subject to a change. This in turn triggers a detuning of the spectral features associated with these parameters [1]. For an FBG sensor, the Bragg reflection peak is the characteristic spectral marker [3], whereas for an FFPI, the resonance transmission peak typically serves as the indicator for spectral changes [4]. In either case, the main goal for improving sensing resolution is to create spectral features as narrow

as possible. In essence, this can be regarded as making wavelength discriminators with the highest possible wavelength selectivity [5].

A widely used metric to gauge the resolving power of a fiber-optic sensor is *strain resolution*, which is defined as the minimum change of length (per unit of the total length) a sensor is able to resolve. Over the years, several techniques have been developed to enhance the strain resolutions of passive fiber-optic sensors [6]–[26]. Two notable examples are phase-shifted FBG and slow-light FBG.  $\pi$ -phase-shifted FBG utilizes a  $\lambda/4$  gap in between two identical Bragg gratings to create a very narrow peak in the middle of the reflection spectrum [6], [7]. This sharp spectral feature has proved to be effective in achieving ultrahigh strain resolution [8]–[12]. In particular, a recent report by Liu *et al.* has demonstrated a strain resolution of  $140 \text{ f}\epsilon/\sqrt{\text{Hz}}$  at 1 kHz by locking a laser to the resonant peak of a  $\pi$ -phase-shifted FBG [12]. Meanwhile, ultrahigh strain resolution has also been realized with extremely narrow slow-light resonance peaks [13]–[18]. These peaks exist near both edges of the band gap of an FBG under the conditions of strong grating-index modulation, low internal loss, optimized apodization of index profile, and a suitable length [13]–[16]. They are referred to as “slow-light” resonances because of the large group delay in the vicinity of these narrow resonances [17]. It has been shown that such ultra-narrow spectral features can lead to ultrahigh sensing resolutions. For example, by probing slow-light resonances, Skolianos *et al.* has demonstrated strain resolutions of  $30 \text{ f}\epsilon/\sqrt{\text{Hz}}$  at 30 kHz and  $110 \text{ f}\epsilon/\sqrt{\text{Hz}}$  at 2 kHz [18].

Generating ultra-narrow resonance peaks from FFPI is an alternative way to achieve UHR optical sensing [19]–[26]. Compared to the approaches based on FBGs, this method does not require highly specialized sensor-fabrication technologies, making it much easier to commercialize. In order to minimize the resonance linewidth of a Fabry-Perot (FP) cavity, *high mirror reflectivity* (high finesse) and *long cavity* (small free spectral range or FSR) are generally desired [27]. However, unique challenges arise in the improvement of both factors in FFPI. First, the end reflectors of most FFPIs are made of FBGs, whose peak reflectivity can typically reach up to 99%. As a result, most of the FFPI sensors reported so far feature finesse below 300 [20]–[22]. Secondly, despite clear superiority of FFPI over free-space FP in compactness and cost [28], [29], the development of UHR FFPI sensors has been hindered by the technical challenge of reliably interrogating long FFPI cavities with lasers. This is because, as the resonance peaks become sharper, the frequency range within which a laser can effectively interrogate an FFPI (typically within a half width of a resonance peak) becomes narrower. As a result, it becomes more difficult for an interrogation laser to maintain the optimum interrogation condition for extended periods; even small perturbations can completely disengage the laser and the FFPI, making the sensor unreliable to operate [30]–[33]. Most of the FFPI-based sensors reported so far are about or less than 20 cm [19]–[24]. A notable work by Gagliardi *et al.* has demonstrated strain resolutions of  $220 \text{ f}\epsilon/\sqrt{\text{Hz}}$  at 1.5 kHz and  $350 \text{ f}\epsilon/\sqrt{\text{Hz}}$  at 5 Hz, which are accomplished by interrogating a 13-cm FFPI with a diode laser frequency-locked to an optical frequency comb (OFC) [34]. The same group has also reported the use of a 50-cm FFPI to achieve a  $60 \text{ p}\epsilon/\sqrt{\text{Hz}}$  resolution at about 900 Hz [25].

Despite these prior efforts, UHR optical sensing based on long FFPI remains to be a challenging area. Meanwhile, recent studies have shown that long fiber Fabry-Perot cavities can serve as highly sensitive temperature [35] and acoustic [36] sensors and they play a vital role in the probing of fundamental thermomechanical fluctuations inherent in optical fibers [26], [37]. In this letter, we present what we believe as the first experimental realization of UHR fiber-optic sensor based on *meter-long, high-finesse* ( $\sim 1000$ ) FFPIs. In doing so, we have also demonstrated direct frequency locking between a diode laser and a 1-m long fiber FP cavity. With only off-the-shelf components, including the FFPI and the interrogation laser, and without any additional laser-frequency stabilization, we have achieved nominal strain resolutions of approximately  $800 \text{ f}\epsilon/\sqrt{\text{Hz}}$  within 1–100 Hz and as low as  $40 \text{ f}\epsilon/\sqrt{\text{Hz}}$  at higher frequencies.

## 2. Experimental Method

The FFPI sensor used in this research is a commercial fiber FP scanning interferometer (Micron Optics, FFP-SI). The structure of the FFPI is shown in Fig. 1(a) [38]. The interferometer body is




Fig. 1. (a) Schematic of the fiber Fabry-Perot interferometer (FFPI) sensor with a 1-m cavity length. (b) A layout of the overall experimental setup (for both laser-cavity locking and strain measurement). Amp: rf amplifier; LD: laser diode; LPF: low-pass filter; PD: photodetector; PM: phase modulator; SG: signal generator; SMF: single-mode fiber. Note that the different inputs toward the DSA and the Oscilloscope represent different channels of the instruments.

a 1-m long single-mode fiber. Its two ends are coated with highly reflective multilayer dielectric mirrors to form an optical cavity. The cavity is specified to have a finesse of 1000. Our independent characterization indicates an actual finesse of 902, with a free-spectral range of 105 MHz and an average full-width-at-half-maximum (FWHM) linewidth of 116 kHz. The FFPI is equipped with a piezoelectric (PZT) stretcher, allowing the cavity length and the resonance peaks to be tuned.

In order to interrogate an FFPI sensor, the probing laser must be able to *reliably* track the motion of a resonance peak. This is especially difficult for a high-finesse, long fiber cavity because of the extremely narrow resonances ( $\sim 100$  kHz in our case). We take on this challenge from two aspects: (i) minimizing the random jitter and drift of the resonance peaks due to environment-induced fluctuations, and (ii) letting the interrogating laser *track* the large but slow drift of the FFPI so the laser can stay on resonance with the cavity for an extended period. To tackle the first task, we thermally and acoustically isolate the sensor from ambient by sealing it inside a fiberglass box, whose interior walls are lined with sound absorbing foams. The box is then placed on a passive vibration-isolation platform (Minus K, BM-1) to eliminate the influence from floor vibration. To accomplish the second goal, we introduce a reference FFPI, which is identical to the sensor FFPI, and package both FFPIs in the same isolation box. We then frequency-lock the interrogation laser to the reference FFPI. Since both FFPIs experience the same environmental perturbations, their resonance peaks have similar drift. Thus, locking the laser frequency to the reference FFPI enables the laser to track the fluctuations of the sensor resonances.

Fig. 1(b) shows a diagram of the entire experimental setup. The interrogation laser is an off-the-shelf, single-frequency diode laser (RIO, Orion), operating at 1557.4 nm with a 6-kHz linewidth and a 10-mW output power. After passing through a polarization controller (PC), the laser output is split into two paths by a 90:10 fiber coupler. The PC is added here due to a slight polarization sensitivity of the FFPIs. The majority of the optical power is coupled into the FFPI sensor (FFPI-1 in Fig. 1), while a small portion of the laser power is directed toward the reference fiber cavity (FFPI-2). The reference arm consists of a typical Pound-Drever-Hall (PDH) frequency locking system [39], preceded by an erbium-doped fiber amplifier (EDFA) for power adjustment. The PDH system operates at 18 MHz and the effective servo bandwidth is 10 Hz. The servo output is used to control the driving current of the diode laser. The particularly low servo bandwidth is intended to allow the laser frequency to track the slow drift of the FFPI resonance without following the high-frequency jitter of the resonance. It should be noted that the fibers connecting FFPI-2 and the PDH system are in the locking loop, so fluctuations in these fibers can in principle affect the PDH error signal. However, such impact is typically very small given the 18-MHz operating frequency of the PDH locking loop (corresponding to a 17-m wavelength). The introduction of the EDFA also adds excess noise to the overall noise floor due to amplified spontaneous emission (ASE). This noise is mitigated




Fig. 2. Frequency locking between the diode laser and FFPI-2: (a) optical transmission of FFPI-2 (solid) and the PDH error signal before and after locking; (b) Fourier spectra of the error signal before locking (dash-dotted), after locking (solid), and under the “drift-over” condition (dashed).

in our experiment by introducing a bandpass filter following the EDFA (not shown in Fig. 1(b)). The EDFA is *not* necessary if the laser has a higher output power.

The optical transmissions through both FFPIs are detected by two identical photodetectors (Thorlabs, DET20C). The detector outputs are monitored with both an oscilloscope and a fast-Fourier-transform dynamic signal analyzer (DSA) (Stanford Research Systems, SR785). Also being monitored on the oscilloscope and the DSA are the PDH error signal as well as the servo output.

### 3. Experimental Result

To perform the experiment, the diode laser is first locked to the reference cavity (FFPI-2). Fig. 2 shows the behaviours of the PDH error signal before and after locking is established. In Fig. 2(a) (lower trace), the transition of the error signal from prior-locking to post-locking is captured in the time domain. At the moment of locking (time 0), the error signal experiences a rapid transient. After that, it quickly settles down to a steady level, albeit with significantly increased high-frequency fluctuations. The presence of a constant level of high-frequency noise in the error signal indicates that the laser frequency is tracking the slow drift of the resonance peak without responding to high-frequency jitters of the cavity. The establishment of laser-cavity locking is also evident from the behaviour of optical transmission through FFPI-2, which is shown by the upper trace in Fig. 2(a). The photodetector output jumps from zero to a steady level at time 0 and remains on that level thereafter, indicating that a stable FFPI-2 transmission is established. This can only happen when the laser frequency and the cavity resonance are locked.

Meanwhile, it is also instructive to examine the behaviors of the error signal in the frequency domain, which are shown in Fig. 2(b). The dash-dotted (orange) trace on the bottom shows the Fourier spectrum of the error signal before locking. Since without locking the laser frequency is generally far away from any cavity resonances, the error signal is effectively zero and its spectrum is dominated by the instrument noise. Once the laser is locked to the cavity, the error signal displays a much-elevated level of noise, as shown by the solid (dark red) trace in Fig. 2(b). This is in agreement with the time-domain observation in Fig. 2(a). An interesting fact revealed by the frequency-domain measurement, however, is a decrease of the error signal below 10 Hz, which is a clear indication of the servo action. This downward bending of error signal spectrum at low frequencies can be more clearly seen on the linear frequency scale as shown in the inset of Fig. 2(b). To further showcase the effectiveness of our frequency locking system, we tune the laser frequency very close to a cavity resonance and measure the error signal spectrum while the resonance peak freely drifts over the free-run laser. The result is shown as the dashed (green) trace in Fig. 2(b). The high-frequency portion of the trace (>20 Hz) overlaps with the locked error signal spectrum, suggesting that they






Fig. 3. (a) FFPI-1 (dashed) and FFPI-2 transmissions during the laser frequency tuning. The laser frequency is eventually parked in the middle of the trailing edge of an FFPI-1 resonance. (b) The high-resolution lineshape of an FFPI-1 resonance is obtained by scanning the relative frequency between the resonance peak and the interrogation laser.

are of the same nature, i.e., dominated by fast jitter of the resonance peak. Below about 20 Hz, the free-run spectrum exhibits a substantial increase due to the relative frequency drift between the laser and the cavity resonance. Such a drift is completely removed once the frequency locking is engaged.

After the laser is locked to the reference FFPI, we tune the laser frequency to match one of the resonance frequencies of the FFPI sensor (FFPI-1). This is done by applying a proper bias voltage across the PZT stretcher mounted on FFPI-2. As the length of the reference cavity is gradually adjusted, the servo automatically adjusts the laser frequency to keep it locked with the cavity resonance. The advantage of this method lies in the fact that the random drift of the two FFPIs has very little impact on the frequency detuning between the interrogation laser and the FFPI sensor, because the two FFPIs experience the same random drift due to their similar ambient conditions. This allows the tuning process to be done in a well-controlled fashion, as demonstrated in Fig. 3(a). The dashed (purple) trace shows the optical transmission through FFPI-1. As the laser frequency scans across a resonance peak, the transmitted power sketches out part of the cavity line shape. For optimum sensing performance, we choose to park the laser frequency on the edge of a resonance peak. This can be seen in Fig. 3(a) as the FFPI-1 transmission stays at a fix level halfway down from the peak. Once the laser tuning is finished, the interrogation laser and the FFPI sensor are able to stably maintain their relative frequency for an extended period. This allows precise strain measurement to be carried out. In the meantime, the locking between the laser and FFPI-2 remains intact throughout this tuning process, as evident from the stable FFPI-2 transmission (solid red trace in Fig. 3(a)). The excellent relative frequency stability between the laser and FFPI-1 also enables an accurate measurement of the transmission line shape for FFPI-1. This is done by periodically scanning the laser frequency across an FFPI-1 resonance and monitoring the transmitted power. Fig. 3(b) shows the measured resonance line shape, whose FWHM agrees with the aforementioned cavity specifications. Such high-resolution characterization would be very difficult to accomplish with conventional spectrometers or tunable lasers.

Measurement of *dynamic* strain is performed by applying a strain modulation to FFPI-1 (i.e., the FFPI sensor) while monitoring the variation of transmitted laser power. Strain modulations of various frequencies and amplitudes are introduced via the PZT in FFPI-1. The actual amounts of strain are calibrated based on the manufacturer-specified PZT response, which has also been independently verified in our experiment. A typical frequency response of the sensor under a single-tone strain modulation (300 Hz in this case) is shown in Fig. 4 inset. Despite a very small strain amplitude of  $52 \text{ p}\epsilon$ , a signal-to-noise ratio (SNR) of 32 dB is obtained with a 2-Hz resolution bandwidth. Repeating such measurement with a number of strain modulation amplitudes leads to a strain-response curve, which is found to be highly linear as shown in Fig. 4.




Fig. 4. FFPI sensor response to dynamic strains (at 300 Hz) of various amplitudes. Inset: Measured strain signal at 52 pε vs. noise floor




Fig. 5. Noise-limited strain resolution for the FFPI sensor over 7 decades of frequencies (10 mHz – 100 kHz). Electronic noise includes contributions from the photodetector, the amplifiers and the DSA. Fiber thermal noise, including both thermodynamic noise ( $>10$  Hz) and thermomechanical noise ( $<1$  kHz), is modelled following the discussion in Ref. [26]. The laser noise, including both intensity and frequency noise, as well as residual environment-induced fluctuations are believed to be the main contributors to the overall sensor noise floor

The noise-limited strain resolution can be determined based on the above strain measurement and a measurement of the sensor noise floor. Fig. 5 shows the resulted strain resolution spectrum over a Fourier frequency range of 10 mHz–100 kHz. Apart from several spurious noise spikes, strain resolution is found to be equal or below  $800 \text{ f}\epsilon/\sqrt{\text{Hz}}$  at any frequency above 2 Hz. In particular, the sensor response stays flat within 1–100 Hz with a nominal strain resolution of approximately  $800 \text{ f}\epsilon/\sqrt{\text{Hz}}$ . The noise spike near 30 Hz is likely due to mechanical or electrical coupling into the diode laser, which should be possible to remove with better isolation or shielding. Moving on to higher frequencies, the strain resolution reaches about  $75 \text{ f}\epsilon/\sqrt{\text{Hz}}$  at 1 kHz,  $60 \text{ f}\epsilon/\sqrt{\text{Hz}}$  at 2 kHz and  $40 \text{ f}\epsilon/\sqrt{\text{Hz}}$  at 23 kHz. These results are better than the strain resolutions achieved with phase-shifted FBGs [12] and slow-light FBGs [18] by roughly a factor of *two*. They also appear to be better than some of the prior results based on FFPI sensors at frequencies above 1 kHz [34]. It should be emphasized here that the long cavity and high finesse of the FFPI sensor are critical factors that enable such high strain resolutions. As a comparison, if a shorter

fiber cavity with a lower finesse, such as the one reported in [25] (50 cm cavity with a finesse of 300), was instead used in the current research, we would see a 6-fold reduction in strain resolution, i.e.,  $4.8 \text{ p}\epsilon/\sqrt{\text{Hz}}$  at 1–100 Hz and  $451 \text{ f}\epsilon/\sqrt{\text{Hz}}$  at 1 kHz (assuming all other conditions remain the same), which would render the scheme much less competitive compared to other UHR techniques.

To gain insight into the causes limiting the strain resolution, the spectra of several background noises are also plotted in Fig. 5. In particular, the measured electronic noise includes contributions from the photodetector, the rf amplifiers and the DSA. The intrinsic fiber thermal noises, which include both the thermodynamic noise ( $>10 \text{ Hz}$ ) and the thermo-mechanical noise ( $<1 \text{ kHz}$ ), are computed based on previously developed theoretical models [26]. It is evident from Fig. 5 that the overall noise floor is well above the respective levels of fiber thermal noise, electronic noise and shot noise. This indicates that laser noises (including both intensity noise and frequency noise), which typically dominate in resonator-based sensing systems [12], [18] are likely the dominant limiting factor for the strain resolution. In addition, residual fluctuations of the FFPI sensor due to environment-induced perturbations and the ASE noise due to the EDFA may also contribute to the overall noise floor.

#### 4. Discussion

It should be emphasized here that the above ultrahigh strain resolutions have been achieved using only an *off-the-shelf* diode laser with a 6-kHz linewidth, without any additional laser stabilization. The modest requirement in laser linewidth is especially interesting considering the fact that such scales of resolution typically require a light source with a linewidth on the order of 100 Hz [12], [18], [34], which can only be achieved with highly specialized narrow-linewidth lasers such as random distributed fiber lasers [12] or with laser-frequency referencing to OFC [34]. This highlights a key advantage of the current scheme, i.e., ultrahigh resolution can be achieved with simple and commercially available light sources, which can potentially make UHR sensing much more accessible to a broad range of users.

Another interesting aspect worth pointing out is the critical role of the reference FFPI. Although strain sensing can also be accomplished by locking the laser directly to the sensor FFPI and probing through the PDH lockbox output, the resulted signal inevitably carries a very large background due to the relative drift between the laser frequency and the FFPI resonance even when the FFPI sensor is put in an isolated environment. This background can largely be removed by the introduction of the reference FFPI, especially at low frequencies. This is because the same relative frequency drift occurs between the laser and *both* FFPIs. As a result, it becomes a *common-mode noise* in a differential-detection scheme. The elimination of this large background (often caused by thermal drift) is imperative in achieving the ultrahigh resolution reported here.

It is important now to examine the application prospect of long FFPI sensors. Some of the potential areas where such UHR sensors can work particularly well include bio-acoustic sensing [40], [41] and biochemical sensing [42], where extremely high signal resolution is often required under typically well-controlled environments. A straightforward way to incorporate the proposed sensing scheme into a realistic sensor design is to attach a section of the long FFPI sensor to a transducer (e.g., microphone, strain gauge, etc.), or to activate a portion of the FFPI with nanoparticles or activation agents. Let the transducer or the activated region be exposed to the environment under test, while the rest of the FFPI sensor and the reference FFPI are hermetically sealed from the ambient. Linked by fiber cables, this sensor unit (including both FFPIs and the transducer) can even be physically separated from the laser and the PDH system, allowing it to serve as a *remote* sensor. We have qualitatively tested this sensing concept by attaching an earphone on the FFPI sensor case and have successfully recovered the audio signal played in the earphone using the above scheme. Finally, it should be stressed that, although the proposed FFPI scheme is demonstrated in strain sensing, its potential applications are not limited to strain measurement. With proper transducers, the method can be used to measure other physical parameters such as pressure, temperature, etc.



## 5. Conclusion

In conclusion, direct frequency locking between a diode laser and a meter-long, high-finesse FFPI has been experimentally demonstrated. The laser assembly is used to interrogate a similar meter-long FFPI sensor and UHR dynamic-strain measurement has been carried out. A nominal, noise-limited strain resolution of  $800 f\epsilon/\sqrt{\text{Hz}}$  has been achieved within 1–100 Hz. Strain resolution further improves to  $75 f\epsilon/\sqrt{\text{Hz}}$  at 1 kHz,  $60 f\epsilon/\sqrt{\text{Hz}}$  at 2 kHz and  $40 f\epsilon/\sqrt{\text{Hz}}$  at 23 kHz, demonstrating better UHR potential than proven techniques such as  $\pi$ -phase-shifted FBGs and slow-light FBGs. Since the current sensor resolution is mainly limited by laser intensity and frequency noise, additional measures in laser stabilization are expected to make further improvement in strain resolution. The work lays out a feasible path toward UHR fiber-optic sensing based on long FFPIs.

## References

- [1] F. T. S. Yu and S. Yin, Eds., *Fiber Optic Sensors*. New York: Marcel Dekker, 2002.
- [2] Z. He, Q. Liu, and T. Tokunaga, "Ultrahigh resolution fiber-optic quasi-static strain sensors for geophysical research," *Photon. Sens.*, vol. 3, no. 4, pp. 295–303, Dec. 2013.
- [3] C. E. Campanella, A. Cuccovillo, C. Campanella, A. Yurt, and V. M. N. Passaro, "Fibre bragg grating based strain sensors: Review of technology and applications," *Sensors*, vol. 18, no. 9, Sep. 2018, Art. no. 3115.
- [4] S. Avino, "Fiber-optic cavities for physical and chemical sensing," *Open Opt. J.*, vol. 7, no. 1, pp. 128–140, Dec. 2013.
- [5] J. Chen, Q. Liu, and Z. He, "Time-domain multiplexed high resolution fiber optics strain sensor system based on temporal response of fiber fabry-perot interferometers," *Opt. Express*, vol. 25, no. 18, Sep. 2017, Art. no. 21914.
- [6] W. Huang, W. Zhang, T. Zhen, F. Zhang, and F. Li, " $\pi$ -phase-shifted FBG for high-resolution static-strain measurement based on wavelet threshold denoising algorithm," *J. Lightw. Technol.*, vol. 32, no. 22, pp. 3692–3698, Nov. 2014.
- [7] J. Chen, Q. Liu, and Z. He, "High-resolution simultaneous measurement of strain and temperature using  $\pi$ -phase-shifted FBG in polarization maintaining fiber," *J. Lightw. Technol.*, vol. 35, no. 22, pp. 4838–4844, Nov. 2017.
- [8] J. Chen, Q. Liu, X. Fan, and Z. He, "Ultrahigh resolution optical fiber strain sensor using dual pound-drever-hall feedback loops," *Opt. Lett.*, vol. 41, no. 5, Mar. 2016, Art. no. 1066.
- [9] J. Guo and C. Yang, "Highly stabilized phase-shifted fiber bragg grating sensing system for ultrasonic detection," *IEEE Photon. Technol. Lett.*, vol. 27, no. 8, pp. 848–851, Apr. 2015.
- [10] D. Gatti, G. Galzerano, D. Janner, S. Longhi, and P. Laporta, "Fiber strain sensor based on a  $\pi$ -phase-shifted Bragg grating and the pound-drever-hall technique," *Opt. Express*, vol. 16, no. 3, pp. 1945–1950, Feb. 2008.
- [11] Q. Liu, M. Wu, J. Chen, and Z. He, "Coherent pound-drever-hall technique for high resolution fiber-optic sensors at low probe power," *J. Lightw. Technol.*, vol. 36, no. 4, pp. 1026–1031, Feb. 2018.
- [12] P. Liu, W. Huang, W. Zhang, and F. Li, "Ultrahigh resolution optic fiber strain sensor with a frequency-locked random distributed feedback fiber laser," *Opt. Lett.*, vol. 43, no. 11, Jun. 2018, Art. no. 2499.
- [13] He Wen, G. Skolianos, S. Fan, M. Bernier, R. Vallee, and M. J. F. Digonnet, "Slow-light fiber-bragg-grating strain sensor with a 280-femtostrain/ $\sqrt{\text{Hz}}$  resolution," *J. Lightw. Technol.*, vol. 31, no. 11, pp. 1804–1808, Jun. 2013.
- [14] G. Skolianos, A. Arora, M. Bernier, and M. Digonnet, "Slow light in fiber Bragg gratings and its applications," *J. Phys. Appl. Phys.*, vol. 49, no. 46, Nov. 2016, Art. no. 463001.
- [15] H. Wen, M. Terrel, S. Fan, and M. Digonnet, "Sensing with slow light in fiber bragg gratings," *IEEE Sens. J.*, vol. 12, no. 1, pp. 156–163, Jan. 2012.
- [16] G. M. Gehring, R. W. Boyd, A. L. Gaeta, D. J. Gauthier, and A. E. Willner, "Fiber-based slow-light technologies," *J. Lightw. Technol.*, vol. 26, no. 23, pp. 3752–3762, Dec. 2008.
- [17] K. Qian *et al.*, "Tunable delay slow-light in an active fiber Bragg grating," *Opt. Express*, vol. 17, no. 24, pp. 22217–22222, Nov. 2009.
- [18] G. Skolianos, A. Arora, M. Bernier, and M. Digonnet, "Measuring attostrains in a slow-light fiber bragg grating," presented at the SPIE OPTO, San Francisco, California, United States, 2016, Art. no. 976317.
- [19] Q. Liu, T. Tokunaga, and Z. He, "Ultra-high-resolution large-dynamic-range optical fiber static strain sensor using pound-drever-hall technique," *Opt. Lett.*, vol. 36, no. 20, pp. 4044–4046, Oct. 2011.
- [20] J. H. Chow, D. E. McClelland, M. B. Gray, and I. C. M. Littler, "Demonstration of a passive subpicostrain fiber strain sensor," *Opt. Lett.*, vol. 30, no. 15, Aug. 2005, Art. no. 1923.
- [21] T. T.-Y. Lam *et al.*, "High-resolution absolute frequency referenced fiber optic sensor for quasi-static strain sensing," *Appl. Opt.*, vol. 49, no. 21, Jul. 2010, Art. no. 4029.
- [22] T. Yoshino, Y. Sano, D. Ota, K. Fujita, and T. Ikui, "Fiber-bragg-grating based single axial mode fabry-perot interferometer and its strain and acceleration sensing applications," *J. Lightw. Technol.*, vol. 34, no. 9, pp. 2241–2250, May 2016.
- [23] W. Huang, W. Zhang, and F. Li, "Swept optical SSB-SC modulation technique for high-resolution large-dynamic-range static strain measurement using FBG-FP sensors," *Opt. Lett.*, vol. 40, no. 7, Apr. 2015, Art. no. 1406.
- [24] G. Gagliardi, M. Salza, P. Ferraro, and P. D. Natale, "Interrogation of FBG-based strain sensors by means of laser radio-frequency modulation techniques," *J. Opt. Pure Appl. Opt.*, vol. 8, no. 7, pp. S507–S513, Jul. 2006.
- [25] G. Gagliardi *et al.*, "Optical fiber sensing based on reflection laser spectroscopy," *Sensors*, vol. 10, no. 3, pp. 1823–1845, Mar. 2010.
- [26] L. Duan, "Thermal noise-limited fiber-optic sensing at infrasonic frequencies," *IEEE J. Quantum Electron.*, vol. 51, no. 2, pp. 1–6, Feb. 2015.

- [27] E. Udd and W. B. Spillman Jr., *Fiber Optic Sensors: An Introduction for Engineers and Scientists*. Hoboken, NJ, USA: Wiley, 2011.
- [28] L. Duan and K. Gibble, "Locking lasers with large FM noise to high-Q cavities," *Opt. Lett.*, vol. 30, no. 24, Dec. 2005, Art. no. 3317.
- [29] T. Yoshino, K. Kurosawa, K. Itoh, and T. Ose, "Fiber-optic fabry-perot interferometer and its sensor applications," *IEEE Trans. Microw. Theory Tech.*, vol. MTT-30, no. 10, pp. 1612–1621, Oct. 1982.
- [30] C. Hu, R. P. Gollapalli, L. Yang, and L. Duan, "Excess phase noise characterization in multifrequency remote clock distribution based on femtosecond frequency combs," *Appl. Sci.*, vol. 5, no. 2, pp. 77–87, Jun. 2015.
- [31] R. E. Bartolo, A. B. Tveten, and A. Dandridge, "Thermal phase noise measurements in optical fiber interferometers," *IEEE J. Quantum Electron.*, vol. 48, no. 5, pp. 720–727, May 2012.
- [32] B. H. Lee *et al.*, "Interferometric fiber optic sensors," *Sensors*, vol. 12, no. 3, pp. 2467–2486, Mar. 2012.
- [33] K. Hsu, C. M. Miller, and J. W. Miller, "Speed-of-light effects in high-resolution long-cavity fiber Fabry–Perot scanning interferometers," *Opt. Lett.*, vol. OL-18, no. 3, p. 235, Feb. 1993.
- [34] G. Gagliardi, M. Salza, S. Avino, P. Ferraro, and P. D. Natale, "Probing the ultimate limit of fiber-optic strain sensing," *Science*, vol. 330, no. 6007, pp. 1081–1084, Nov. 2010.
- [35] M. Ding, D. J. Richardson, and R. Slavik, "Long length fibre fabry-perot interferometers and their applications in fibre characterization and temperature sensing," in *Proc. Conf. Lasers Electro-Opt. Europe Eur. Quantum Electron. Conf.*, Munich, Germany, 2019, p. 1.
- [36] B. Liu, J. Lin, H. Liu, Y. Ma, L. Yan, and P. Jin, "Diaphragm based long cavity fabry–perot fiber acoustic sensor using phase generated carrier," *Opt. Commun.*, vol. 382, pp. 514–518, Jan. 2017.
- [37] L. Duan, "General treatment of the thermal noises in optical fibers," *Phys. Rev. A*, vol. 86, no. 2, Aug. 2012, Art. no. 023817.
- [38] Skyadmin, "Support," *Micron Opt.* 2017. [Online]. Available: <http://www.micronoptics.com/products/filters-lasers/support/>. Accessed: Apr. 11, 2019.
- [39] R. W. P. Drever *et al.*, "Laser phase and frequency stabilization using an optical resonator," *Appl. Phys. B*, vol. APB-31, no. 2, pp. 97–105, Jun. 1983.
- [40] J. G. V. Teixeira, I. T. Leite, S. Silva, and O. Frazão, "Advanced fiber-optic acoustic sensors," *Photon. Sens.*, vol. 4, no. 3, pp. 198–208, Sep. 2014.
- [41] Z. Altintas, W. M. Fakanya, and I. E. Tothill, "Cardiovascular disease detection using bio-sensing techniques," *Talanta*, vol. 128, pp. 177–186, Oct. 2014.
- [42] A. Urrutia, J. Goicoechea, and F. J. Arregui, "Optical fiber sensors based on nanoparticle-embedded coatings," *J. Sens.*, vol. 2015, pp. 1–18, 2015.